

Table 9
WAC 246-290-490
High Health Cross-Connection Hazard Premises
Requiring Premises Isolation by AG or RPBA

Agricultural (farms and dairies)

Beverage bottling plants

Car Washes

Chemical plants

Commercial laundries and dry cleaners

Premises where both reclaimed water and potable water are provided

Film processing facilities

Food processing plants

Hospitals, medical centers, nursing homes, veterinary, medical and dental clinics and blood plasma centers

Premises with separate irrigation systems using the purveyor's water supply and with chemical addition †

Laboratories

Metal plating industries

Mortuaries

Petroleum processing or storage plants

Piers and docks

Radioactive material processing plants or nuclear reactors *

Survey access denied or restricted

Wastewater lift stations and pumping stations

Wastewater treatment plants *

Premises with an unapproved auxiliary water supply interconnected with the potable water supply.

† For example: parks, playgrounds, golf course, cemeteries, estates, etc.

* RPBA's for connections serving these premises are acceptable only when used in combination with an in-plant approved air gap; otherwise, the purveyor shall require an approval air gap at the service connection.